

# EYEWASH / SHOWER INSPECTION RECORD

PI: \_\_\_\_\_ Room: \_\_\_\_\_

**NOTES:**

- Eyewash units and Showers must be tested monthly.
- Post Inspection Record near Eyewash unit (If lab has more than one eyewash unit, Post sign on inside of Main entrance door).
- Lids covering outlet heads should be kept closed when not in use

**Instructions:**

- Run the units for 2 minutes, ensuring:
  - there is sufficient water flow
  - the hands-free mechanism is functioning
- Initial the appropriate box below to document a passing inspection
- If inspection fails, notify all users and call Facilities Management: 683-4269 for repairs.

**Exposure:**

- **Should an exposure occur, flush the affected eye(s) for 15 minutes.**
- **To ensure adequate flushing, hold eyelid(s) open and roll the eyeball.**



Year: _____		Year: _____		Year: _____	
Date of Inspection	Testers Initials	Date of Inspection	Testers Initials	Date of Inspection	Testers Initials

Replacement Inspection Records can be found on EHS website:  
[www.odu.edu/ehs](http://www.odu.edu/ehs)  
 “Forms & Pamphlets” then Laboratory